

## Edwards Court

Rowlandsway, Wythenshawe, Manchester M22 5SF

### Fire Risk Assessments

The 'in-scope' buildings have Type 3 surveys undertaken unless a more intrusive one is recommended such as behind cladding or within loft spaces for instance, when further surveys will be requested. This block has Type 3 surveys undertaken on an annual basis. The

Fire Risk Surveys are carried out by 'Total Fire Group' who are BAFE and FIA accredited and have been procured from the Procurement Framework 'Procure Plus Holdings' via a Fire Risk and Mitigation works framework. The main contact there is Darren Baird, Group Director on 01204 697990 [www.totalfiregroup.org](http://www.totalfiregroup.org)

A separate compartmentation survey was also undertaken in 2020 as a separate exercise to specifically review all risers and compartmentation areas that were then rectified.

The Fire Risk Assessments pick up any compartmentation breaches which are tracked through on the FRA portal 'Aurora' to completion and sign off by the relevant directors for those managers.

The fire Risk Rating Matrix used to assess the fire risk can be seen below:

		LIKELY CONSEQUENCES OF FIRE			
		Subjective Fire Risk Rating	Slight Harm	Moderate Harm	Serious Harm
LIKELIHOOD OF FIRE OUTBREAK	Highly Unlikely	Negligible Risk	Tolerable Risk	Moderate Risk	
	Unlikely	Tolerable Risk	Moderate Risk	Substantial Risk	
	Likely	Moderate Risk	Substantial Risk	Intolerable Risk	