

Completion Certificate for 1891 – Brookway Court

We Argus Fire Protection Company Ltd hereby certify that we have completed on 20th November 2019

An Automatic fire Sprinkler system which has been installed, tested and commissioned inline with the British standard 9251: 2014 – Fire Sprinkler systems for domestic & residential.

The Following list of properties have been refused access too:

Flat 1, Flat 2 and Flat 82

Number of Sprinklers	Type	Response	Temperature	K-factor
590	Extended Coverage Sidewall	SR	74 Degree C	80

other relevant information

The system has been designed and installed to the general requirements of BS9251: 2014

The system consists of 1 No. Main Pump wired directly from the primary single phase 415v incoming supply.

We have provided 17 No. Flow switches to each of the floors.

Where the sprinkler system has been refused, we have capped off the sprinkler feed mains outside of the flats ready for future connections.

This has also been configured so that on operation of a flow switch notification will be sent to the alarm panel on the ground floor detailing the level of the operating flow switch. There is also a flashing beacon / sounder on top of the ground floor panel which will give both a visual and audible alarm.

Date Sprinkler System Commissioned / Left Operational – 20th November 2019

Client's Acceptance:

.....
Signature / Name

..... Date :.....
Position

Argus Fire Protection Co Ltd:

Kenny Winstanley – Senior Project Manager

.....
Signature / Name / Position